

## **ADDENDUM 2**

**Elise Gianoglio**

**14145 Racine Circle, Magalia , CA 95954**

- 1.** The write up discusses the replacement of the front steps. What material should be used for the new steps?

*The new steps should have a level concrete land from the steps to the new retaining wall. The new steps could be poured concrete with a no slip surface (exposed aggregate, etc.), the retaining wall material on a firmly compacted base or pressure treated lumber with an adequate anchoring point at the top of the steps. Contact the Owner to see what her preference would be.*