

**ADDENDUM 1**  
**DEVONSHIRE APARTMENTS**  
**WESCOTT ROAD, COLUSA, CA95932**

1. The foam roofing specification calls for 2.25 inches of foam, this is a lot more than usual, is this amount correct?

***NO, This is a typo, the correct amount should be 1.25 inches.***

---