

ADDENDUM 2
February 27, 2020
NEW MAINTENANCE BUILDING
384 MILES AVE.
YUBA CITY, CA 95991

- 1. On the electrical it shows the panel mounted to a wall that is in the phase 2 construction. Are we just stubbing up the conduit and leaving the wire rolled up on the floor?**

Yes, make sure there is enough wire left to make the connection in the panel at a later date.

- 2. Should the current bid include the grading, striping, path of travel, etc. for ADA be included in the bid?**

Yes, sidewalks, fencing changes, path of travel and other site improvements should be included at this time. All exterior work will be completed at this time.